

**ENERGY LABEL SPECIFICATION**

<b>Suppliers name</b>	Deekax Air Oy		
<b>Model identifier</b>	DIVK-C99 CDRH-125 R, DIVK-C99 CDRH-125 L		
<b>SEC, kWh/(m<sup>2</sup>.a)</b>	cold	average	warm
	-73,19	-36,59	-13,00
<b>SEC-class</b>	A+	A	E
<b>Declared topology</b>	RVU/BVU		
<b>Type of drive</b>	Variable speed		
	2		
<b>Type of heat recovery</b>	Recuperative		
<b>Thermal efficiency of heat recovery %</b>	81,1		
<b>Maximum flow rate , m<sup>3</sup>/h</b>	349		
<b>Electric power input of the fan drive (W)</b>	239		
<b>Sound power level (Lwa)</b>	34		
<b>Reference flow rate , m<sup>3</sup>/s</b>	0,068		
<b>Reference pressure difference (Pa)</b>	50		
<b>SPI, W/(m<sup>3</sup>/h)</b>	0,30		
<b>The general classification</b>	Ducted ventilation unit		
<b>Control factor</b>	Centralized as needed		
<b>Maximum internal leakage rate %</b>	2		
<b>Maximum external leakage rate %</b>	1,5		
<b>Filter change</b>	In user manual and service interval reminder on the control panel		
<b>Internet address</b>	<a href="http://www.deekaxair.fi">www.deekaxair.fi</a>		
<b>AEC (the annual electricity consumption) kWh /a</b>			
	cold	9,0	
	average	3,7	
	warm	3,2	
<b>AHS (the annual heating saved) kWh</b>			
	cold	85,9	
	average	43,9	
	warm	19,9	

